



KEY DEPOSITS INTENDED FOR THE RESCUE DEPARTMENT

The owner of the fire alarm system shall acquire and install key deposits in the building they manage. The Western Uusimaa Rescue Department uses the ABLOY PROTEC2 CLIQ key system in their key deposits. The key deposits must be purchased from an authorised Abloy dealer.

The key deposits must be installed according to the security instructions published by Finance Finland:
[Pelastustoimen avainsäilöt](#) (finnish)

The key deposit may only be installed in a property approved by the rescue department. Generally, key deposits are only installed in properties equipped with special fire safety equipment (e.g., automatic fire alarms or extinguishing systems connected to the Emergency Response Centre). In other cases, the matter should be discussed with the rescue department.

Property's external key deposits

The key deposit is installed by embedding the deposit outside the property, in a visible location, approximately 2 meters above the standing surface. The key deposit must be installed carefully according to the manufacturer's instructions. If the building material of the property is not suitable for embedding, the key deposit must be attached by through bolts, following the manufacturer's instructions.

A route key leading to the fire alarm system is placed in the external key deposit.

Property's internal key deposits

In compliance with the manufacturer's instructions, another key deposit must be installed inside the property. The key deposit contains the route key to the interior doors of the property that lead to the necessary premises. Alarm data must be transferred from the key deposit to a continuously supervised and manned location.

In new properties, more detailed locations for key deposits must be separately agreed on with a Rescue Department representative and recorded in the life cycle document of the fire alarm system.

Once a new key deposit has been installed, the Rescue Department will seal the keys and lock cylinder into the key deposit. You can book this service by calling 029 151 2112 (switchboard).

If your property has a key deposit intended for the Rescue Department that has another key system, it must be immediately replaced with the ABLOY PROTEC2 CLIQ key system. The old key deposit must be delivered to a lock shop for disposal.

Nina Piela-Tallberg, Head of Risk Management

Accident Prevention, Western Uusimaa Rescue Department

For more information:

On-duty fire inspector, Western Uusimaa Rescue Department

029 151 2512

palotarkastaja.lu@pelastustoimi.fi